



PROTECTION OF WIRING DURING CONSTRUCTION

ALL ELECTRICAL WIRING AND EQUIPMENT APPROVED FOR USE IN DRY LOCATIONS ONLY SHALL BE PROTECTED FROM THE WEATHER DURING BUILDING CONSTRUCTION. (*Article 110-11 1996 nec*).

Protection from the weather is interpreted to be as follows:

1. The roof sheathing completed and felted in,
2. The exterior walls covered with proper felting or paper, and
3. All of the windows are installed.

THESE ARE GUIDELINES FOR THE MINIMUM PROTECTION REQUIREMENTS OF THE NEC. BASED ON INDIVIDUAL PROJECT CONDITIONS, SIZE AND SHAPE OF THE BUILDING OR STRUCTURE, THE FIELD INSPECTOR'S REQUIREMENT MAY DIFFER.